

# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 0082806

Days Creek School P O Box 10 Days Creek, OR 97429	Project: Drinking Water	Date Reported: 09/10/20 Date Received: 08/28/20 09:15 Sampled By: Louis Calvert
	Client Contact: Matt Giles PWSID#: 4192101	

### Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
0082806-01	Sample Location: #1 / Breakroom									
	Lead	1030	ND	mg/L	0.002	0.015	08/28/20 06:45	09/04/20	DST	
	Copper		0.022	mg/L	0.010	1.3	08/28/20 06:45	09/04/20	DST	
0082806-02	Sample Location: #2 / HS Hall DF									
	Lead	1030	0.005	mg/L	0.002	0.015	08/28/20 06:20	09/04/20	DST	
	Copper		0.011	mg/L	0.010	1.3	08/28/20 06:20	09/04/20	DST	
0082806-03	Sample Location: #3 / Rm 208									
	Lead	1030	0.017	mg/L	0.002	0.015	08/28/20 07:15	09/04/20	DST	CON-1
	Copper		0.036	mg/L	0.010	1.3	08/28/20 07:15	09/04/20	DST	
0082806-04	Sample Location: #4 / Concession Stand									
	Lead	1030	ND	mg/L	0.002	0.015	08/28/20 00:00	09/04/20	DST	
	Copper		0.094	mg/L	0.010	1.3	08/28/20 00:00	09/04/20	DST	
0082806-05	Sample Location: #5 / Kitchen Sink									
	Lead	1030	0.004	mg/L	0.002	0.015	08/28/20 07:20	09/04/20	DST	
	Copper		0.023	mg/L	0.010	1.3	08/28/20 07:20	09/04/20	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Director



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: <http://ChemLab.cc>  
ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 0082806

### Qualifiers and Definitions

CON-1	Results confirmed by duplicate analysis.
DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

---

Tom Williams, Laboratory Director