

Water Testing Results - Douglas County SD 15

Action Level is 0.015 mgL

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Break room Sink		6/13/2019	0.009
High School Drinking Fountain		6/13/2019	ND
Science RM 208 Sink		6/13/2019	0.009
Concession Stand		6/13/2019	ND
Kitchen Sink		6/13/2019	0.002

ND = Non Detect - Lead level is below the set detection limits of 0.002 mgL