Lead in Water Test Results Summary: Building 1

Notes:

- The lead in water Action Level is 15 parts per billion (ppb).

 Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of [#] ppb.

Legend:

- Test results equal to or greater than the Action Level of 15 ppb are highlighted in red and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results near the Action Level of 15 ppb (11.99 to 14.99 ppb) are highlighted in yellow and precede a "Med" (Medium) value in the "Initial Level" or "Final Level" column.

		Initial	Initial Test	Initial	Final	Final Test	Final
Fixture Location Description	Fixture ID #	Test Date	Result (ppb)	Level	Retest Date	Result (ppb)	Level
[enter description]	[enter ID #]	[enter date]	[enter result]	[autofill]	[enter date]	[enter result]	[autofill]
Room 201	19930100-001CF	9/29/2023	6.8	Low	N/A	6.8	Low
Room 202	19930100-001CF	9/29/2023	3.7	Low	N/A	3.7	Low
Room 203	19930100-001CF	9/29/2023	13	Med	N/A	13	Med
Room 204	19930100-001CF	9/29/2023	2.4	Low	N/A	2.4	Low
Room 205	19930100-001CF	9/29/2023	9.8	Low	N/A	9.8	Low
Elementary DF	19930100-001DW	9/29/2023	ND	Low	N/A	ND	Low
Room 207	19930100-001CF	9/29/2023	1.6	Low	N/A	1.6	Low
Gym DF	19930100-001DW	9/29/2023	ND	Low	N/A	ND	Low
Gym Lobby	19930100-001DW	9/29/2023	ND	Low	N/A	ND	Low
AG DF	19930100-001DW	9/29/2023	ND	Low	N/A	ND	Low