

UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 9061306

Days Creek School
 P O Box 10
 Days Creek, OR 97429

Project: Drinking Water

Date Reported: 06/21/19

Date Received: 06/13/19 09:18

Sampled By: Louis

Client Contact: Louis Calvert

PWSID#: 4192101

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
9061306-01	Sample Location: #1 Breakroom Sink									
Lead		1030	0.009	mg/L	0.002	0.015	06/13/19 08:00	06/14/19	JJL	
Copper			0.025	mg/L	0.010	1.3	06/13/19 08:00	06/14/19	JJL	
9061306-02	Sample Location: #2 HS Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.015	06/13/19 07:50	06/14/19	JJL	
Copper			0.112	mg/L	0.010	1.3	06/13/19 07:50	06/14/19	JJL	
9061306-03	Sample Location: #3 Rm 208 Sink									
Lead		1030	0.009	mg/L	0.002	0.015	06/13/19 07:58	06/14/19	JJL	
Copper			0.053	mg/L	0.010	1.3	06/13/19 07:58	06/14/19	JJL	
9061306-04	Sample Location: #4 Concessions Sink									
Lead		1030	ND	mg/L	0.002	0.015	06/13/19 08:10	06/14/19	JJL	
Copper			0.089	mg/L	0.010	1.3	06/13/19 08:10	06/14/19	JJL	
9061306-05	Sample Location: #5 Kitchen Sink									
Lead		1030	0.002	mg/L	0.002	0.015	06/13/19 08:03	06/14/19	JJL	
Copper			0.065	mg/L	0.010	1.3	06/13/19 08:03	06/14/19	JJL	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 9061306

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager