

UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 1080610

Days Creek School
 P O Box 10
 Days Creek, OR 97429

Project: Drinking Water
 Project #: Days Creek in House Lead and Copper
 Client Contact: Matt Giles
 PWSID#: 4192101

Date Reported: 08/13/21
 Date Received: 08/06/21 09:26
 Sampled By: Matt Giles

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
1080610-01	Sample Location: #1 Rm 201									
	Lead	1030	9	ppb	2	15	08/06/21 07:00	08/10/21	DST	
	Copper		ND	ppb	10	1300	08/06/21 07:00	08/10/21	DST	
1080610-02	Sample Location: #2 Rm 202									
	Lead	1030	6	ppb	2	15	08/06/21 07:02	08/10/21	DST	
	Copper		74	ppb	10	1300	08/06/21 07:02	08/10/21	DST	
1080610-03	Sample Location: #3 Rm 203									
	Lead	1030	17	ppb	2	15	08/06/21 07:02	08/10/21	DST	
	Copper		ND	ppb	10	1300	08/06/21 07:02	08/10/21	DST	
1080610-04	Sample Location: #4 Rm 204									
	Lead	1030	4	ppb	2	15	08/06/21 07:05	08/10/21	DST	
	Copper		171	ppb	10	1300	08/06/21 07:05	08/10/21	DST	
1080610-05	Sample Location: #5 Rm 205									
	Lead	1030	13	ppb	2	15	08/06/21 07:04	08/10/21	DST	
	Copper		33	ppb	10	1300	08/06/21 07:04	08/10/21	DST	
1080610-06	Sample Location: #6 Elementary DF									
	Lead	1030	ND	ppb	2	15	08/06/21 07:01	08/10/21	DST	
	Copper		28	ppb	10	1300	08/06/21 07:01	08/10/21	DST	
1080610-07	Sample Location: #7 Rm 207									
	Lead	1030	4	ppb	2	15	08/06/21 07:04	08/10/21	DST	
	Copper		76	ppb	10	1300	08/06/21 07:04	08/10/21	DST	
1080610-08	Sample Location: #8 Gym Drinking Fountain									
	Lead	1030	4	ppb	2	15	08/06/21 07:12	08/10/21	DST	
	Copper		166	ppb	10	1300	08/06/21 07:12	08/10/21	DST	
1080610-09	Sample Location: #9 Gym Lobby DF									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 1080610

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	ppb	2	15	08/06/21 07:13	08/10/21	DST	
Copper			54	ppb	10	1300	08/06/21 07:13	08/10/21	DST	
1080610-10	Sample Location: #10 AG DF									
Lead		1030	ND	ppb	2	15	08/06/21 07:15	08/10/21	DST	
Copper			136	ppb	10	1300	08/06/21 07:15	08/10/21	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 1080610

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager