

UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 5091905

Days Creek School
P O Box 10
Days Creek, OR 97429

Project: Drinking Water
Project #: Lead Testing 2025

Client Contact: Matt Giles

Date Reported: 09/25/25
Date Received: 09/19/25 10:35
Sampled By: Matt Giles

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
5091905-01	Sample Location: RM 201									
Lead (ppb)		1030	12.8	ppb	1.0	15	09/19/25 06:05	09/23/25	DST	
5091905-02	Sample Location: RM 202									
Lead (ppb)		1030	3.6	ppb	1.0	15	09/19/25 06:02	09/23/25	DST	
5091905-03	Sample Location: RM 203									
Lead (ppb)		1030	8.4	ppb	1.0	15	09/19/25 06:04	09/23/25	DST	
5091905-04	Sample Location: RM 204									
Lead (ppb)		1030	1.3	ppb	1.0	15	09/19/25 06:02	09/23/25	DST	
5091905-05	Sample Location: RM 205									
Lead (ppb)		1030	4.8	ppb	1.0	15	09/19/25 06:04	09/23/25	DST	
5091905-06	Sample Location: RM 207									
Lead (ppb)		1030	1.2	ppb	1.0	15	09/19/25 06:05	09/23/25	DST	
5091905-07	Sample Location: Gym Lobby									
Lead (ppb)		1030	ND	ppb	1.0	15	09/19/25 06:15	09/23/25	DST	
5091905-08	Sample Location: Gym DF									
Lead (ppb)		1030	ND	ppb	1.0	15	09/19/25 06:17	09/23/25	DST	
5091905-09	Sample Location: Elementary DF									
Lead (ppb)		1030	ND	ppb	1.0	15	09/19/25 06:06	09/23/25	DST	
5091905-10	Sample Location: Elementary BR									
Lead (ppb)		1030	6.0	ppb	1.0	15	09/19/25 06:01	09/23/25	DST	
5091905-11	Sample Location: Gym Men's BR									
Lead (ppb)		1030	4.3	ppb	1.0	15	09/19/25 06:16	09/23/25	DST	
5091905-12	Sample Location: Gym Girl's BR									
Lead (ppb)		1030	11.6	ppb	1.0	15	09/19/25 06:18	09/23/25	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 5091905

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
5091905-13	Sample Location: AG Sink									
Lead (±)		1030	1.3	ppb	1.0	15	09/19/25 06:20	09/23/25	DST	
5091905-14	Sample Location: AG DF									
Lead (±)		1030	ND	ppb	1.0	15	09/19/25 06:30	09/23/25	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 5091905

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager